

***Annual Drinking Water Quality Report for 2021***  
***Dover Ridge Estates Water System***  
***Stowe Dr, Poughquag, NY 12570***  
***(Public Water Supply ID# 1302804)***

**INTRODUCTION**

To comply with State regulations, Dover Ridge Estates Water will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact VRI Environmental Services at (845) 677-3839. We want you to be informed about your drinking water.

**WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The water system serves a population of approximately 235 individuals through approximately 67 service connections. The water source is groundwater wells, which are located on the Dover Ridge Estates property. Groundwater from two deep-drilled wells is pumped into the pump house where it is disinfected with sodium hypochlorite (a 12.5 % chlorine solution), then passes through a twin softening unit for radium removal and then moves to a storage tank. A third well also located on the property, is presently inactive. Water is then conveyed to a hydropneumatic tank via booster pumps. Automatic controls maintain the proper level within the storage tank and pressure in the hydropneumatic tank.

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to the consumers is, or will be contaminated. See section "Are there contaminants in our drinking water?" for a list of contaminants that have been detected, if any. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment has rated our water source as having an elevated susceptibility to microbials, nitrates, salts, sulfate, industrial solvents and other industrial contaminants. These ratings are due primarily to the close proximity of the wells to permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) and the residential and agricultural land use and related activities in the assessment area. In addition, the wells draw from fractured bedrock and the overlying soils may not provide adequate protection from potential contamination. While the source water assessment has rated our wells as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards for microbial contamination.

The county and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. A copy of the assessment can be obtained by contacting us as noted below.

### ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, nitrate, principal organic compounds, primary inorganic compounds, lead and copper, disinfection byproducts, and radiologicals. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800) 426-4791 or the Dutchess of Behavioral and Community Health at (845) 486-3404.

| Table of Detected Contaminants |                  |                |                                   |                  |      |                                  |   |
|--------------------------------|------------------|----------------|-----------------------------------|------------------|------|----------------------------------|---|
| Contaminant                    | Violation Yes/No | Date of Sample | Level Detected (Avg/Max) (Range)  | Unit Measurement | MCLG | Regulatory Limit (MCL, TT or AL) | Likely Source of Contamination  |
| Gross Alpha                    | No               | Quarterly 2021 | 3.65<br>(Range = 1.82 – 5.25)     | pCi/L            | 0    | 15                               | Erosion of natural deposits.  |
| Combined Radium 226 & 228      | No               | Quarterly 2021 | 1.54<br>(Range = 0.66 – 2.62)     | pCi/L            | 0    | 5                                | Erosion of natural deposits.  |
| Beta                           | No               | Quarterly 2021 | 3.71<br>(Range = 0.947 – 6.59)    | pCi/L            | 0    | 50 *                             | Decay of natural deposits and man-made emissions.   |
| Uranium                        | No               | Quarterly 2021 | 1.84<br>(Range = 1.73 – 2.04)     | pCi/L            | 0    | 20                               | Erosion of natural deposits.  |
| Copper **                      | No               | 8/20/2020      | 0.134<br>(Range = 0.0349 – 0.143) | mg/L             | 1.3  | AL=1.3                           | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives. |
| Lead ***                       | No               | 8/20/2020      | 0.585<br>(Range = ND – 1.17)      | ug/L             | 0    | AL = 15                          | Corrosion of household plumbing system; Erosion of natural deposits.                                    |



| Contaminant | Violation Yes/No | Date of Sample | Level Detected (Avg/Max) (Range) | Unit Measurement | MCLG | Regulatory Limit (MCL, TT or AL) | Likely Source of Contamination   |
|-------------|------------------|----------------|----------------------------------|------------------|------|----------------------------------|--|
| Barium      | No               | 9/21/2021      | 0.0111                           | mg/L             | 2    | 2                                | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.  |
| Nickel      | No               | 9/21/2021      | 0.000753                         | mg/L             | n/a  | n/a                              |  |
| Nitrate     | No               | 3/10/2021      | 0.455                            | mg/L             | 10   | 10                               | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |

**Footnotes:**

\* The State considers 50 pCi/L to be the level of concern for beta particle.

\*\* The level presented represents the 90<sup>th</sup> percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 5 samples were collected at your water system and the 90<sup>th</sup> percentile value is the reported value. The action level for copper was not exceeded at any of the sites tested.

\*\*\* The level presented represents the 90<sup>th</sup> percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the lead values detected at your water system. In this case, 5 samples were collected at your water system and the 90<sup>th</sup> percentile value is the reported value. The action level for lead was not exceeded at any of the sites tested.

**Definitions:**

**Non - Detects (ND)** - Laboratory analysis indicates that the constituent is not present.

**Milligrams per liter (mg/L)** – Corresponds to one part of liquid in one million parts of liquid (parts per million – ppm).

**Micrograms per liter (ug/L)** – Corresponds to one part of liquid in one billion parts of liquid (parts per billion – ppb).

**Action Level (AL)** - The concentrations of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.

**Picocuries per liter (pCi/L)** – A measure of the radioactivity in water.

**WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. We are required to present the following information on lead in drinking water.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. Dover Ridge Estates Water is responsible for providing high quality drinking water, but can not control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800) 426-4791 or at <http://www.epa.gov/safewater/lead>.

### **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2021, our water system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

### **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbial pathogens are available from the Safe Drinking Water Hotline (800) 426-4791.

### **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ♦ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ♦ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ♦ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ♦ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ♦ Turn off the tap when brushing your teeth.
- ♦ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ♦ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

### **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have any questions.